

Submitter No: 900

Submitter Name:
Transpower

Date Received: 4 / 9 /17

Conditions

- (3) The width of the telecommunication device must not exceed 1.8 metres.
- (4) The telecommunication device must extend no more than 2.5 metres above the height of the structure.

22 Restricted discretionary activities

- (1) Installing or modifying a telecommunication device on a transmission line support structure of an existing transmission line is a restricted discretionary activity if 1 or both of the conditions in regulation 21(3) and (4) are breached.

Matters to which discretion restricted

- (2) Discretion is restricted to the following matters in relation to a restricted discretionary activity under this regulation:
 - (a) the size, height, and number of telecommunication devices and associated telecommunication cables; and
 - (b) visual and landscape effects.

Signs

23 Permitted activities

- (1) Installing or modifying a sign on a transmission line support structure of an existing transmission line that is intended to identify the structure or its owner, or is intended to help with safety or navigation, is a permitted activity if the applicable condition in subclause (2) or (3) is complied with.

Conditions

- (2) The signs on a transmission line support structure that are intended to identify the structure or its owner must together cover an area of no more than 1 m².
- (3) The signs on a transmission line support structure that are intended to help with safety or navigation must together cover an area of no more than 6 m².

24 Restricted discretionary activities

- (1) Installing or modifying a sign on a transmission line support structure of an existing transmission line that is intended to identify the structure or its owner, or is intended to help with

safety or navigation, is a restricted discretionary activity if the applicable condition in regulation 23(2) or (3) is breached.

- (2) Installing or modifying a sign next to a transmission line support structure of an existing transmission line that is intended to identify the structure or its owner, or is intended to help with safety or navigation, is a restricted discretionary activity.

Matters to which discretion restricted

- (3) Discretion is restricted to the following matters in relation to a restricted discretionary activity under this regulation:
- (a) visual effects; and
 - (b) the effects on services and infrastructure.

*Transmission line support structures:
Discharges from blasting and applying
protective coatings*

25 Permitted activities

- (1) Blasting a transmission line support structure of an existing transmission line, or preparing the structure to receive protective coatings, is a permitted activity if all of the applicable conditions in subclauses (3) to (9) are complied with.
- (2) Applying protective coatings to a transmission line support structure of an existing transmission line is a permitted activity if the condition in subclause (10) is complied with.

Conditions

- (3) Blasting must not be done within 50 metres of a water body or the coastal marine area.
- (4) Blasting must not be done—
- (a) within 50 metres of a public road; or
 - (b) within 100 metres of an occupied building.
- (5) Abrasive material used in abrasive blasting must contain no more than 5% free silica by dry weight.
- (6) Waste and debris resulting from abrasive blasting must be removed from the site of the blasting to the extent practicable.
- (7) Dry abrasive blasting—
- (a) must be done no more than 1 metre above ground level; and